

C. DUKES SCOTT  
EXECUTIVE DIRECTOR

1401 Main Street, Suite 900  
Columbia, SC 29201



DAN E. ARNETT  
CHIEF OF STAFF

Phone: (803) 737-0800  
Fax: (803) 737-0801

shudson@regstaff.sc.gov

*Shannon Bowyer Hudson*  
Counsel for ORS

September 12, 2008

**VIA ELECTRONIC FILING**

Charles L. A. Terreni, Esquire  
Chief Clerk & Administrator  
Public Service Commission of South Carolina  
101 Executive Center Drive  
Columbia, South Carolina 29210

Re: Request for Investigation to Determine Whether a Regulation Should Be Promulgated  
Requiring Relocation of Certain Meter Sets or Installation of Splash Guards on These  
Meter Sets

**Third Supplemental Operator Responses**  
**Docket No. 2005-270-G**

Dear Mr. Terreni:

On the enclosed table, please find the third semi-annual compilation of responses provided by jurisdictional Gas System Operators ("operators") in South Carolina pursuant to the Public Service Commission of South Carolina ("Commission") Orders<sup>1</sup> issued in Docket No. 2005-270-G and specifically Order No. 2007-589. Those operators who have completed remediation are not included in the responses.

Respectfully submitted,

*Shannon Bowyer Hudson*  
Shannon Bowyer Hudson

Enclosure

cc: Maureen O. Floyd, Esquire  
James H. Jeffries IV, Esquire  
Kerry McTigue, Esquire  
K. Chad Burgess, Esquire  
Mitchell M. Willoughby, Esquire  
Paul W. Dillingham, Esquire

---

<sup>1</sup> Orders No. 2007-589, 2007-475, 2006-310, 2006-168, and 2006-168(A).

# THIRD SUPPLEMENTAL OPERATOR RESPONSES

SEPTEMBER, 2008

PSC Docket No. 2005-270-G

OPERATORS THAT HAD NOT COMPLETED TYPE 12 METER SET REMEDIATION AS OF 3/15/08	Date of Supplemental Reply	1. Type 12 Meter Sets on System	2. Type 12 Meter Sets Subject to Service Regulatory Vent Moisture Intrusion and Freezing	3. Remaining Number to be Reconfigured*	4. Remaining Meters to have Splash Guards Installed*	5. Reconfiguration Schedule	6. Splash Guard Installation Schedule	7. Number Reconfigured to Date	8. Number of Splash Guards Installed to Date	9. Forecast for Completing Reconfigurations	10. Forecast for Completing Splash Guard Installations	Comments
Clinton Newberry NGA	9/2/08	14,561	14,561	7,123	0	May 2009	N/A*	7,438	N/A	May 2009	N/A	Possibility that work may be completed before May, 2009.
Lancaster Co. NGA	9/3/08	12,000	2,040	Ongoing	Ongoing	In progress daily	In progress daily	401	789	In progress daily	2010	In the process of changing over Moisture Intrusion Regulators during Service Orders, Meter Orders, Leak Orders and during repairs resulting from Leak Survey activity.
York Co. NGA	9/5/08	157	See Comments	See Comments	See Comments	Ongoing	12/31/2010	25	80	Ongoing	12/31/2010	Servicemen are reconfiguring meters subject to moisture accumulation (if the vent piping has not already been modified) as they come across them in the system. This will be ongoing as meter or regulator change outs become necessary, until they are eliminated from York Co. NGA's system. Along with the normal Leak Survey, the above schedule helps ensure all meter sets are visited every three years, as required for atmospheric corrosion.

\* N/A = Not Applicable.